

A. PLUMBING CONTRACTOR TO PROVIDE HARD A.C.R. OR TYPE "L" COPPER DRAIN LINES FOR WALK-IN

B. PLUMBING CONTRACTOR TO PROVIDE INDIVIDUAL DRAIN LINE FOR EACH EVAPORATOR UNLESS OTHERWISE

REFRIGERATION AND FREEZER, PITCHED 1/2" PER FOOT OF RUN. IN FREEZER, UNHEATED DRAIN LINE MUST

BE OUTSIDE OF INSULATION TO PREVENT FREEZING. TRAP DRAIN LINE OUTSIDE OF REFRIGERATED SPACE TO

4. PLUMBING CONTRACTOR

A VOID ENTRANCE OF WARM AND MOIST AIR.

C. ALL PLUMBING INSTALLATION SHALL BE IN ACCORDANCE WITH LOCAL CODES.

FACTORY WIRING -

TO DATA SWITCH

FIELD WIRING -----

MULTIPLE EVAP COILS IN THE SAME ROOM

MUST BE BONDED TO EACH AND CONNECTED

7/8" NOM. COPPER—

 $\begin{array}{c} 23-1056 \\ \hline \text{Date} \\ 8-30-2023 \\ \hline \text{Drawn By} \end{array} \qquad \begin{array}{c} \text{Sheet number} \\ \hline \\ R-2 \\ \end{array}$

THE SYSTEM SHALL HAVE A FACTORY MOUNTED RECESSED, PRE-WIRED, WEATHER RATED ETL LISTED ELECTRICAL

ELECTRICAL COMPONETS SHALL INCLUDE BUT NOT LIMITED TO COMPRESSORS, TIME CLOCKS, CIRCUIT BREAKERS, CONTACTORS, RELAYS, FAN MOTORS AND OTHER CONTROLS OR COMPONENTS DEEMED NECESSARY FOR OPERATION

OF THE SYSTEM.

REFRIGERATION LINES:

CONTROL PANEL WITH MAIN DISCONNECT FOR A SINGLE POINT ELECTRCAL CONNECTION BY THE ELECTRICAL CONTRACTOR.

REFRIGERATION LINES SHALL BE A.C.R. GRADE TYPE 'L" AND BE PRE-PIPED AND EXTENDED IN A NEAT AND ORDERLY

MANNER TO ONE SIDE OF THE SYSTEM FOR A SINGLE-POINT CONNECTION. ALL PIPING SHALL BE ANCHORED AND SECURED WITH UNISTRUT CLAMPS. EACH SYSTEM SHALL BE PRESSURIZED, CHECKED, TESTED AND SHIPPED WITH DRY NITROGEN.